

Information table according to Annex II of the Commission Regulation (EU) 2015/1189 of April 28, 2015

Model identifier: <b>Smart Fire 15 / 3 bar</b>							
Stocking mode: Automatic: it is recommended that the boiler be operated with a hot water storage tank of a volume of at least 300 litre							
Condensing boiler: no							
Solid fuel cogeneration boiler: no				Combination boiler: no			
Fuel	Preferred fuel:	Other suitable fuel(s):	$\eta_s$	Seasonal space heating emissions			
				PM	OGC	CO	NO <sub>x</sub>
				mg/m <sup>3</sup>			
Log wood, moisture content ≤ 25%	no	no					
Chipped wood, moisture content 15-35 %	no	no					
Chipped wood, moisture content > 35 %	no	no					
Compressed wood in the form of pellets or briquettes	yes	no	83%	7	4	141	150
Sawdust, moisture content ≤ 50 %	no	no					
Other woody biomass	no	no					
Non-woody biomass	no	no					
Bituminous coal	no	no					
Brown coal (including briquettes)	no	no					
Coke	no	no					
Anthracite	no	no					
Blended fossil fuel briquettes	no	no					
Other fossil fuel	no	no					
Blended biomass (30-70 %)/fossil fuel briquettes	no	no					
Other blend of biomass and fossil fuel	no	no					

**Characteristics when operating with the preferred fuel only:**

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Useful heat output				Useful efficiency			
At rated heat output	$P_n$	17.0	kW	At rated heat output	$\eta_n$	86.7	%
At 30 %/of rated heat output, if applicable	$P_p$	5.1	kW	At 30 %/of rated heat output, if applicable	$\eta_p$	86.6	%
For solid fuel cogeneration boilers: Electrical efficiency				<b>Auxiliary electricity consumption</b>			
				At rated heat output	$e_{l_{max}}$	0.053	kW
				At 30 %/of rated heat output, if applicable	$e_{l_{min}}$	0.019	kW
At rated heat output	$\eta_{el,n}$		%	Of incorporated secondary emission abatement equipment, if applicable			kW
				In standby mode	$P_{SB}$	0.003	kW

Contact details	HKS Lazar Spółka z o. o. 44-335 Jastrzębie-Zdrój ul. Wodzisławska 15B, Poland
-----------------	--